

3 Part CSI Formatted Specification Guide
Zandur Resilient Flooring Products
Manufactured by Zandur
888.397.2656
www.zandur.com

Section 09 65 16.33

SOPHROS SOLID RUBBER SHEET

DOCUMENT #942s

THE FOLLOWING DOCUMENT IS A GUIDE FOR CREATING YOUR CSI FORMATTED 3-PART ARCHITECTURAL GUIDE SPECIFICATIONS.

ZANDUR ACCEPTS NO LIABILITY FOR ANY DAMAGES RESULTING FROM THE USE OF THIS DOCUMENT OR RELATED SPECIFICATIONS. PRIOR TO USE OF THIS DOCUMENT, ENSURE THAT YOU HAVE OBTAINED ALL UP TO DATE PUBLICATIONS AND SPECIFICATIONS FROM ZANDUR. MANUFACTURER RESERVES THE RIGHT TO CHANGE SPECIFICATIONS WITHOUT NOTICE FOR PRODUCT IMPROVEMENTS OR OFFERING.

THE SPECIFIER IS RESPONSIBLE FOR PRODUCT SELECTION, ACCURACY OF ALL PROJECT SPECIFICATIONS AND USE OF PROPER SPECIFICATION DATA.

1.GENERAL

1. RELATED DOCUMENTS

- A. Drawings and provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

2. SUMMARY

- A. Section Includes:
 - 1) Rubber Sheet Flooring

3. SUBMITTALS

- A. Product Data: Submit product data including manufacturers general specification sheet for each product specified.
- B. EPD Submittals:
 - 1) Submit Product and Factory Specific EPD including GWP and Carbon Data.
- C. LEED Submittals:

Section 09 65 16.33

RESILIENT RUBBER FLOORING SHEET SOPHROS SOLID RUBBER

1) Product Data for each LEED credit where product meets qualifications: For adhesives, include printed statement of VOC content and chemical components.

- D. Samples for Initial Selection: Submit representative selection of samples for finish, color and shade.
- E. Product Schedule: For resilient products. Use same designations indicated on Drawings.

4. QUALITY ASSURANCE

- A. Mockups: Provide resilient products with mockups specified in other Sections.
- B. Documents. Submit the following:
 - 1. Test reports showing compliance with specified performance and physical characteristics
 - 2. Installation and Maintenance instructions.
- C. Samples for Verification: For each product specified, provide two samples in manufacturer's standard submittal size samples for site verification prior to installation of color, shade, texture, and pattern required.

5. DELIVERY, STORAGE, AND HANDLING

- A. Material shall be stored in a cool, dry, enclosed space with a minimum temperature of 45°F. Prior to installation, verify job site conditions are maintained between 65°F and 75°F with a relative humidity between 45% and 65%. These conditions must be maintained for 72 hours prior to, during and 72 hours after installation. Temporary heating may not be used during acclimation or installation.

6. PROJECT CONDITIONS

- A. Install resilient flooring after other finishing work, including painting and installation of ceiling systems has been completed.
- B. Maintain ambient temperature and humidity on job site in the range between 65°F and 75°F with a relative humidity between 45% and 65%.
- C. Install flooring only when interior HVAC systems are functioning and building is fully enclosed.

7. WARRANTY

- A. Manufacturer's Warranty: Submit manufacturers standard warranty documentation.

Section 09 65 16.33

RESILIENT RUBBER FLOORING SHEET SOPHROS SOLID RUBBER

8. ADDITIONAL MATERIALS

- A. Attic Stock: Deliver 5% additional materials from same production run to owner for use at a future time should repair and/or replacement of a damaged area of the floor be required.

PART 2 - PRODUCTS

2.0 RESILIENT FLOORING

A. SOLID RUBBER SHEET

1. SOPHROS SOLID VULCANIZED RUBBER SHEET

a. Manufactured By:

Zandur	Phone:	888.397.2656
26 Kelley Dr		610.932.4390
Front Royal, VA 22630	Tech:	888.397.2656
Web: www.zandur.com	Samples:	888.397.2656
email: sales@zandur.com	Fax:	540.987.5049

- b. Manufactured with nDur Nitrile Rubber.
- c. SBR and Latex Free
- d. Meets ASTM F 1859 Standard Specification for Rubber Sheet Flooring
- e. Manufactured with environmentally compatible, fade resistant pigments and natural fillers.
- f. Warranty: 1 Year Manufacturing Defect, 20 Year Wear Through
- g. Overall thickness (Specify Thickness):
 - 1) 2.5mm
 - 2) 3.0mm (Non-Standard)
- h. Sheet Size (specify)
 - 2) 3.94' W x 39.4' L
- i. Color (Specify):
 - 1) (Specify manufacturers Color Name and Numerical Reference)
 - 2) Custom Color (Specify color using manufacturers custom sample code)
- j. ASTM D 3389 Standard Test Method for Coated Fabrics Abrasion Resistance: < 1.00 gram weight loss.
- k. ASTM D 2047, Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring: Coefficient of friction test values shall equal or exceed 0.96 (dry) and 1.20 (wet)
- l. ASTM F 970, Standard Test Method for Static Load Limit – Exceeds Requirement.
- m. ASTM E 648, Standard Test method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source – Class I
- n. ASTM D2240, Shore A Hardness: Min 85
- o. ASTM F 925 extended, Chemical Resistance: No more than slight: change in surface color, dulling or attack.

Section 09 65 16.33

RESILIENT RUBBER FLOORING SHEET SOPHROS SOLID RUBBER

- p. ASTM E 662, Smoke Density: <300
- q. ASTM G 21, Mold Growth: Anti-Microbial
- r. Meets California Section 01350 indoor air quality test
- s. PVC, Virgin SBR, Phthalate, chlorine and halogen-free.
- t. Meets qualification criteria for LEED credits MR4.1, MR4.2, MR 6.0 and IEQ4.3.
- u. Oil and Grease Resistance: Yes
- v. Declare Red List Free

2.1 INSTALLATION MATERIALS

- A. Trowelable Leveling and Patching Compounds: Latex-modified, **Portland** cement based or blended hydraulic cement based formulation.
- B. Adhesives: As recommended in current manufacturers installation instructions.
 - 1. Manufacturers recommended Acrylic Adhesive for light traffic commercial
 - 2. Manufacturers recommended Two Part Urethane for moderate to heavy commercial traffic, heavy rolling or point loads.
 - 3. Manufacturers recommended Releasable Adhesive for use over access flooring panels where releasable properties are desired.

3.EXECUTION

1. EXAMINATION

- A. Examine substrates, with installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the work.
- B. Verify that finishes of substrates comply with tolerances and other requirements specified in other Sections and that substrates are free of cracks and other imperfections, are smooth and level within tolerance specified by manufacturer and are free of oils, waxes, paint or other materials that might interfere with adhesion of resilient products.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

2. PREPARATION & RESPONSIBILITIES

A. SITE REQUIREMENTS:

- 1) **WARNING:** Do not sand, dry sweep, dry scrape, drill, saw, bead-blast, or mechanically chip or pulverize existing resilient flooring, backing, lining felt, asphalt “cutback” adhesive, or other adhesive. These products may contain asbestos fibers and/or crystalline silica. Avoid creating dust. Inhalation of such dust is a cancer and respiratory tract hazard. Smoking by individuals exposed to asbestos fibers greatly increases the risk of serious bodily harm. Unless positively certain that the product is a non-asbestos containing material, you must presume it contains asbestos. Regulations may require that the material be tested to determine asbestos content.

Section 09 65 16.33

RESILIENT RUBBER FLOORING SHEET SOPHROS SOLID RUBBER

2. Flooring must be installed on a substrate that is permanently dry, clean, smooth and structurally sound. It must be free of contaminants such as paint, oil, wax, mold, adhesive residues, sealers or any other materials that may interfere with adhesive bonding.
3. Prior to installation, perform an adhesive bond test according to manufacturers current instructions.
4. Flooring is not intended to be installed over existing floor coverings and is not warranted for such use unless approved by manufacturer. Existing flooring or Treads must be removed or (if installed on a wood subfloor) covered with 1/4" or 1/2" plywood.
5. All Sub-floors shall be flat to within 3/16" in 10' and shall be patched or skim coated with a hard setting underlayment compound to ensure substrate is completely smooth. Cementitious underlayment compounds must have a minimum compressive strength of 3,000 psi. Do not apply patching material over existing adhesives. Manufacturer is not responsible for any claims submitted on floors where patching materials have been applied over adhesive residue or existing floor coverings regardless of manufacturer instructions. After patching or skimming is complete, floor must be sanded or scraped to remove any trowel marks or other inconsistencies which may telegraph through the finished flooring material. Follow manufacturers guidelines for product mixing and use instructions. Gypsum products are not recommended for use.
6. Preparation of Wood Sub-Floors
 - a. Prepare wood sub-floor per ASTM F 710, *Standard practice for installation and preparation of panel type underlayment to receive resilient flooring*, as it relates only to approved wood underlayments.
 - b. Floor covering products may be installed over 3/8" or greater A/C grade plywood or underlayment board such as Tecply or Halex (Arctic or Baltic Birch).
 - c. Products are not approved for installation over panel underlayments such as Masonite, luan, particle board, OSB, cementitious underlayment panel, wood underlayment with knots or coated wood.
 - d. Follow manufacturers' instructions for installation regarding fastening pattern and joint spacing. Do not install underlayment with screws.
 - e. Once installed, patch subfloor with cementitious material as instructed in current manufacturers' instructions.
7. Preparation of Concrete Sub-Floors
 - a. Concrete sub-floors shall be prepared in accordance with ASTM F 710 *Standard practice for preparing concrete sub-floors to receive resilient flooring*.
 - b. Concrete sub-floors must be clean as specified. Pay specific attention to possible presence of a sealer which must be removed. It is highly recommended to shot blast or bead blast existing concrete sub-floors prior to installation to remove sealers, adhesives and/or any other surface contaminants.
 - c. Concrete sub-floors on or below grade must have a moisture retarder and all concrete subfloors, regardless of age, must be tested for the moisture vapor emission rate and relative humidity to ensure the sub-floor is suitable for floor covering installation.
 - d. Testing of concrete shall be performed **ONLY** when the building is enclosed and when the HVAC system has been in operation for at least 7 days. Furthermore, job-site temperature and humidity must be at the level expected during normal use or in the range of 65°F to 85°F and 45% to 55% relative humidity.

Section 09 65 16.33

RESILIENT RUBBER FLOORING SHEET SOPHROS SOLID RUBBER

- e. Moisture tests must be performed at a rate of 3 for the first 1,000 square feet and then 1 additional test per additional 1,000 square feet.
- f. Moisture Vapor Emission Rate shall not exceed level specified in current manufacturers sub-floor preparation guide as tested in accordance with ASTM F 1869 (Calcium Chloride Test).
- g. Concrete Relative Humidity shall not exceed the percentage specified in manufacturers current specification guide as tested in accordance with ASTM F 2170 (Relative Humidity Probe Test).
- h. Sub-Floor pH must be tested with wide range pH paper and verified to be no greater than 9. Test as per ASTM F-710.
- i. Level sub-floor as specified
- j. Allow patching materials to dry naturally without the use of direct air or temporary HVAC.
- k. Flooring may be installed over terrazzo floors, however terrazzo must be bead or shot blasted to ensure adhesion.
- j. Flooring products may be installed over in-floor, hot water radiant heat systems. Specific installation instructions shall be obtained from manufacturer and implemented accordingly.

3. RESILIENT SHEET INSTALLATION

- A. Comply with manufacturer's written instructions for installing resilient rubber flooring.
- B. Install with the appropriate adhesive depending upon use and exposure to surface moisture.

4. CLEANING AND PROTECTION

- A. Comply with manufacturer's written instructions for cleaning and protection of resilient products.
- B. Perform the following operations immediately after completing resilient product installation:
 - 1) Remove adhesive and other blemishes from exposed surfaces.
 - 2) Sweep and vacuum surfaces thoroughly.
 - 3) Floor Finishes: Finishes are not required for use where auto scrubbers are used. For applications where only mopping and infrequent scrubbing occur or where exposure to potential staining hazards is possible, a finish is advisable as specified by manufacturer's instructions.
- C. Protect resilient products from mars, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- D. Limit traffic for 24 hours after installation unless approved by manufacturer otherwise.
- E. Heavy traffic, rolling loads, or furniture placement prior to 72 hours after installation is prohibited

END OF SECTION 09.65.19